



DEVICE LEGEND

☉ LIGHT 120V FROM PANEL CIRCUIT #3

⊕ RECEPTACLE 120V FROM PANEL CIRCUIT #1

DESIGN DATA

CONTINUOUS CAPACITY: 12075 LBS/HR. FROM/AT 212°F

DESIGN PRESSURE: 250 PSIG

HEATING SURFACE: 1757 FT2 (ASME)

FUEL REQUIREMENTS

NATURAL GAS:

SUPPLY PRESSURE:

CONSUMPTION: 14645 SCFH

#2 OIL CONSUMPTION: 105 GPH

POWER REQUIREMENTS:

480 VOLT 3 PHASE

INSTALLATION:

OUTDOOR SERVICE

SHIPPING: #

OPERATING: #

NOTES:

1. SEE SHEET "M9" FOR GENERAL NOTES AND MATERIAL LIST.

| Designed by M.L. GISH | Checked by B. SCOGGINS | Approved by - date 5/15/09 | Filename 350-250-M1 | Date 5/15/09 | Scale N/A | | | | | | | | | | | | |
|--|---------------------------|-------------------------------|---|-----------------|--------------|-------------|--|--|--|--|--|--|--|--|------------|--------------|-------------|
| | | | 350 H.P., TRAILER MOUNTED BOILER SYSTEM EQUIPMENT ARRANGEMENT & PIPING CONNECTIONS RB# 759-130 | | | | | | | | | | | | | | |
| <table border="1"> <thead> <tr> <th>REV</th> <th>DATE</th> <th>BY</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table> | | | REV | DATE | BY | DESCRIPTION | | | | | | | | | 350-250-M1 | Edition 1 | Sheet M1 |
| REV | DATE | BY | DESCRIPTION | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |

Three I Engineering, Inc.
Engineers/Architects
2425 W. INDIANA ST., EVANSVILLE, IN (812) 423-8800
THREE I ENGINEERING JOB NUMBER: 08352A